

INCORPORATED 1952
(845) 351-4745 (Voice)
(845) 351-2668 (Fax)
Website: tuxedopark-ny.gov

VILLAGE BOARD MEETING
THIRD WEDNESDAY OF EACH MONTH

VILLAGE OF TUXEDO PARK
P.O. BOX 31
80 LORILLARD ROAD
TUXEDO PARK, NEW YORK 10987

DPW Report
March 28, 2018 to May 15, 2018

Roads

1. Cold patched potholes.
2. Worked on filter at the water plant.
3. Worked with O&R tree crew.
4. Plowed snow on 4/2/18.
5. Removed fallen tree on Fox Hill Road.
6. Picked up sticks and branches around Village.
7. Unloaded filter media and stored at the sewer plant garage (26 pallets).
8. Cleaned up 2 trees that fell at the Wee Wah Beach Club.
9. Emptied storage tank at Ridge Road for interior cleaning, sealing, and installation of cathodic protection.
10. Installed new sand media in filter #2 at the water plant.
11. Fixed roadway to the Mountain Farm pump station.
12. Built and installed new shelving at the Police Station for new electronic equipment.
13. Cleaned drains and catch basins around the Village.
14. Picked up the wood around the Village left by the O&R cutting crew.
15. Cut back brush on the access road to the Mountain Farm storage tank.
16. Re-graded driveway and back parking lot at the Police Station.
17. Patched Nursery Road at the location of a water main break.
18. Cut down large uprooted tree at DPW shop.
19. Removed leaning tree at the Racetrack. Also, installed rip rap stone at the outfall of 5 pipes at the Racetrack.
20. Began to sweep Village roads.
21. Cut grass at the Main Gate.

Water

1. Regularly checked Mountain Farm pump station and pressure regulator in Town.
2. Did daily maintenance and testing at the water plant.
3. Andy from Napp Electric came and worked on filter bed #2 pressure switches.
4. Continued fixing water meters and water pads.
5. Removed soda ash chemical tubing in chemical room to unclog line. (Tubing working fine at this time).
6. Received chemical shipments.
7. Turned water off at 2 Circuit Road for plumber. Turned water back on when plumber was finished.
8. Started installing seasonal water meters.
9. Mailed out monthly water reports to O.C.H.D.
10. Installed new 12" gate valve at the Ridge Road storage tanks.
11. Finished work on filter #2 at the water plant and put filter back in service on 4/20/18.
12. Repaired water main break on Mountain Road.
13. Filled storage tank on Ridge Road after interior work was completed. Tank will be put back in service after testing requirements from the Orange County Health Department are completed.

Sewer

1. Regularly checked Turtle Point Road sewer pump station.
2. Did daily maintenance and testing at sewer plant.
3. Received chemical shipments.
4. Sucked out sewer pumping pit at water plant.
5. Removed sludge from sewer plant.
6. Steam cleaned trailers and boats.
7. Took bi-monthly sewer samples for D.E.C.
8. Prepared monthly sewer reports for D.E.C.
9. Ran sewer jet down manhole at Mountain Farm pump station.