

**VILLAGE OF TUXEDO PARK**  
P.O. BOX 31  
80 LORILLARD ROAD  
TUXEDO PARK, NEW YORK 10987

**DPW Report**  
**June 19, 2018 – July 17, 2018**

**Roads**

1. Watered newly planted trees on Tuxedo Road.
2. Cut down several trees at the Wee Wah Beach property and the DPW property.
3. Cleaned drains and catch basins.
4. Worked with Nelson Tree Service (O&R) on tree removals.
5. Worked at Racetrack clearing mulch and preparing area to be seeded. Also picked up brush.
6. Weed wacked Wee Wah Road.
7. Repainted traffic lines at entrance to main gate.
8. Sanded and painted railings at the Keep and Lodge.
9. Cut Grass throughout the Village.
10. Installed dog waste station at the Wee Wah Beach.
11. Patched holes on Clubhouse Road from horse trough to Race Track.
12. Picked up generator at the Dow property.
13. Put out signed cones and barricades for the fireworks display.
14. Weed wacked Tuxedo road from the Tuxedo Club to the main gate.
15. Weed wacked the embankment to the Wee Wah Dam.

**Water**

1. Finished reading water meters in the Village and Town.
2. Continued repairing water meters and meter pads.
3. Turned water on at 19 River Road.
4. Did daily maintenance and testing at the Water Plant.
5. Took bi-monthly water samples for OC Health Dept.
6. Received chemical shipments.
7. Made chemicals as needed.
8. Prepared monthly water reports for the OC Health Dept.
9. Changed out weekly charts.
10. Greased pumps and motors.
11. Met with contractor at former Take a Break site to discuss relocation of water shut off valve.
12. Installed new chemical feed pump and began using new coagulant PACL 2040 in place of Aluminum Sulfate.

13. Installed new air valve on filter number 2, transferred plastic beads from one side of the filter to the other to allow painters to paint bead side of tank.
14. Turned water on at Bartlett pool house.

### **Sewer**

1. Took bi-monthly sewer samples for DEC.
2. Prepared monthly sewer reports for DEC.
3. Received chemical shipments.
4. Removed sludge from sewer plant.
5. Regularly checked Turtle Point road sewer pump station.
6. Performed daily maintenance and testing at the Sewer Plant.